

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1574:163 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Models Unimode 10 fire alarm control unit. Power-limited; non-coded, local, remote station and central station service; manual, automatic, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

Unimode 10	Control Unit
CAC-10F	Class A Connector
PRT-24	Printer Interface Module
NAC-REM	Bell/Relay Expander Module
XRM-24	Transformer
LED-10IM	Annunciator Interface Module
DP-5210UD	Front Cover

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Inc. Label

APPROVAL: Listed as a fire alarm control unit for use with separately listed electrically compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: 1. For Alarm Verification Feature, the maximum Retard/Rest/Restart shall be adjusted to 30 seconds or less.

2. Formerly 7165-0085:177

XLF: 7165-0075:177

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**